

SERIES 800 HORIZONTAL SLIDING VINYL WINDOWS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. New Construction Windows.
 - 1. Sliding windows

1.2 RELATED SECTIONS

- A. Section 05450: Cold Formed Metal Framing.
- B. Section 06100: Rough Carpentry.
- C. Section 06200: Finish Carpentry.
- D. Section 07460: Siding.
- E. Section 07920: Joint Sealants.

1.3 REFERENCES

- A. AAMA/WDMA/CSA 101/I.S.2/A440-2017 North American Fenestration Standard / Specification For Windows, Doors, And Skylights.
- B. ASTM E 283-19 Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Differences Across the Specimen.
- C. ASTM E 547-00 Standard Test Method For Water Penetration Of Exterior Windows, Skylights, Doors, and Curtain Walls By Cyclic Static Air Pressure Difference.
- D. ASTM E 330-14 Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls Uniform Static Air Pressure Difference.
- E. ASTM E 2190-19 Standard Specification for Insulating Glass Unit Performance and Configuration.
- F. ANSI/NFRC 100-2020 – Procedure for Determining Fenestration Product U-Factors.
- G. ANSI/NFRC 200-2020 – Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.

- B. Product Data: Submit the following documents for each type of window.
 - 1. Manufacturer's technical data, product descriptions and installation guides.
 - 2. Elevation for each style window specified indicating its size, glazing type, muntin type and design.
 - 3. Manufacturer's head, jamb and sill details for each window type specified.
- C. Verification Samples: Provide operating units of each style window specified.
 - 1. Verification samples may be operating scaled-down mock-ups of actual-size units.
 - 2. Operating hardware such as balances, sash locks and weather-stripping.
 - 3. Verification samples will be returned to manufacturer's representative at project closeout.
- D. Test Reports: Submit certified independent testing agency reports indicating window units meet or exceed specified performance requirements.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Minimum ten (10) years producing vinyl (PVC) windows.
- B. Installer Qualifications: Utilize an installer having demonstrated experience on projects of similar size.
- C. Provide window units independently tested and found to be in compliance with AAMA/WDMA/CSA 101/I.S.2/A440-2017 performance standards listed above.
- D. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Finish areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship and color are approved by Architect.
 - 3. Refinish mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver windows to project site in undamaged condition; handle windows to prevent damage to components and to finishes.
- B. Store products in manufacturer's unopened packaging, out of direct sunlight or high temperature locations, until ready for installation.

1.7 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.8 WARRANTY

- A. Submit manufacturer's standard warranty against defects in workmanship and materials.
 - 1. Limited Lifetime Limited Transferable warranty on extruded solid vinyl member and component parts. Insulated glass is warranted against material obstruction of transparency resulting from film formation or dust collection on the interior glass surfaces for a period of twenty (20) years. Consult warranty for complete details.

2. The warranty period for commercial project work such as apartments, housing authorities and other buildings not used by individual homeowners is 10 years, covering all vinyl, glass and component parts. Consult warranty for complete details.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Crystal Window & Door Systems located at: 31-10 Whitestone Expressway, Flushing, NY 11354; Tel: 718.961.7300; Fax: 718.460.4594; Email: marketing@crystalwindows.com ; Web: www.crystalwindows.com
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- D. Substitutions must be submitted to Architect two weeks prior to bid opening.

2.2 HORIZONTAL SLIDER - CRYSTAL SERIES 820-2 (Two-Lite) & CRYSTAL SERIES 820-3 (Three-Lite) (New Construction)

- A. Performance:
 1. Rating: R-PG30 - Test Size: 1524 mm x 1372 mm (60 inches x 54 inches) in accordance with AAMA/WDMA/CSA 101/I.S.2/A440-2017.
 2. Air Test Performance Requirements:
 - a. Air infiltration maximum 0.30 cfm/ft² per square foot at 1.57 psf pressure differential when tested in accordance with ASTM E283 for sliding sealed products.
 3. Water Test Performance Requirements:
 - a. No uncontrolled water leakage at 4.60 psf static pressure differential when tested in accordance with ASTM E547.
 4. Forced Entry: Grade 10 in accordance with ASTM F 588.
 5. Thermal Transmittance: The following values are in accordance with NFRC 100, 200 and 500:
 - a. With Low-E / Argon: U-Factor - 0.29 Btu/Hr-Ft²-F, SHGC – 0.30
- B. Operation: Right sash (from inside) of two-lite slider, left and right sashes of three-lite slider shall move left and right. The left sash (from inside) of two-lite slider and the middle sash of three-lite slider shall be fixed in the frame. All movable sashes shall lift out for easy cleaning or re-glazing.
- C. Materials: All vinyl extrusions shall be rigid 100% virgin PVC. Jambs and sash rails shall have a main wall thickness of 0.060". Frame profile shall have tubular hollows for strength and thermal efficiency. Sash profiles shall be tubular extruded.
- D. Frame construction: Frame shall have an integral pre-punched nailing fin along the perimeter. All corners shall be mitered and fusion welded. Frame depth shall be 2-7/8".

- E. Sash construction: All sash corners shall be mitered and fusion welded. There shall be integral interlock at the meeting rails. Sashes shall have internal metal reinforcements at meeting rails in all sash heights. Movable sash shall have integral pull handle that will be the full height of sash.
- F. Glazing: Sash shall utilize 3/4" thick insulating glass consisting of two sheets of 3/32" thick argon filled Low-E glass with a metal spacer system (Intercept) equipped with desiccant. A butyl sealant shall be extruded around the entire perimeter of the spacer to achieve a seal. The fixed sash shall be interior glazed, and the movable sash shall be exterior glazed. Both sashes shall be back bedded with glazing tape, and utilize snap-in glazing beads.
- G. Screen construction: The screen frame shall be rollformed of aluminum with all corners keyed. For two-lite slider, standard screen shall be a half screen. For three-lite slider, screen shall be either a full screen or two pieces that cover the two movable sashes area. There shall be with a full-length handle on left or right rail that can be used to take out the screen. The screen mesh shall be charcoal fiberglass held-in-place with a flexible spline. Two stainless steel spring clips shall be applied at the opposed side of handle rail.
- H. Hardware: Sash lock shall be cam type and finished to match the vinyl extrusion color. Sash lock shall be fastened at the lock rail by two sheet-metal color matched screws. Double locks will be standard on window over 24" in height. Two tandem Nylon roller sets shall be recessed into each bottom rail of the movable sash.
- I. Weatherstripping: High-density woven pile shall be used in combination with continuous polyethylene rigid seal to minimize air infiltration.
- J. Finish: Shall be solid vinyl in off white. Optional Black or Bronze Two-tone Cap stock
- K. Options: Grids – Colonial, Georgian, Applied, Prairie (Flat) and Diamond aluminum in-glass in white, black or two tone colors are available. Glazing – Duralite spacer, glass: obscure, clear anneal and special tempered glass can be used. Field muller or factory muller units are available

PART 3 EXECUTION

3.1 EXAMINATION

- A. Contractor must verify rough opening size is of sufficient size to receive window unit and complies with manufacturer's requirements for opening clearances.
- B. Confirm that sill plate is level.
- C. Architect must be notified of unacceptable conditions before proceeding with installation.

3.2 INSTALLATION

3.3 Contractor must install window unit in accordance with manufacturer's printed instructions.

- A. Apply sealant around perimeter of window unit between nail fin and exterior sheathing of wall.

Crystal[®]

WINDOW & DOOR
SECTION 08560

- B. Install window unit level and plumb. Center window unit in opening and secure window unit by nailing through nail fin and screw through jambs as indicated in manufacturer's instructions.
- C. Flash window in accordance with AAMA 100-12 "Standard Practice for Installation of Windows with a Mounting Flange in Stud Frame Construction".
- D. Insulate between window frame and rough opening with suitable insulation.

3.4 ADJUSTING

- A. Installer must adjust units for smooth operation without binding or racking.
- B. Installer must adjust sash locks and screens for smooth operation.

3.5 CLEANING

- A. Clean soiled surfaces and glass prior to substantial completion.

3.6 PROTECTION

- A. Protect window unit from damage until substantial completion. Repair or replace damaged units.

END OF SECTION